



LITTLE LAKE CITY SCHOOL DISTRICT

ADDENDUM #3

BID No. 18-19-006

Proposition 39 Exterior LED Lighting at 7 Elementary Schools

NOTICE TO BIDDERS: The following changes, additions and clarifications have been made to the original bid documents for the above referenced project (“Project”) and shall be incorporated into the bidder’s response. The bidder shall acknowledge receipt of this Addendum where provided on the BID FORM. All other aspects of the work and services from the original bid documents shall remain unchanged. In case of conflict between the bid documents and this Addendum, this Addendum shall govern.

QUESTIONS AND CLARIFICATIONS

Question: 1. The license require to bid this project as a prime contractor?

Clarification: The required license information is listed on the General Information section of the RFB.

Question: 2. Is the project still bidding on June 11 at 10:00 AM?

Clarification: Yes.

Question: 3. Is it possible for me to obtain a copy of the sign in sheet after the pre bid meeting on May 23 at 10:00 AM? Could you send me the sign in sheet if there is?

Clarification: You can obtain a copy of the Pre-bid conference (Job walk) Sign-in Sheet at the Districts website: <https://www.llcsd.net/currentbids>.

Question: 4. Do you have an updated plan holders list and addenda released at this point? Could you send me if there is?

Clarification: There is no plan holders list at this point. Addendums are posted at the Districts website: <https://www.llcsd.net/currentbids>.

Question: 5. Do you happen to know how much is the estimate cost of this project?

Clarification: There is no estimate available for this project.

Question: 6. Within the site survey files there are links to pictures. Will these pictures be made available?

Clarification: The links are broken, and we do not anticipate being able to make the pictures available in a usable form.

Question: 7. We missed the Job Walk on May 23rd for this bid as the RPF got to us just a couple of days ago, but would like very much to participate in this project. Is there any way for you to arrange a short visit for us only to one of the schools so that we will be able to participate?

Clarification: Any Contractor bidding on the Project who fails to attend the entire mandatory bid conference and job walk will be deemed a non-responsive bidder and will have its bid returned unopened.

Question: 8. How many lights are in each classroom?

Clarification: 10 in each room 20 total for both.

Question: 9. What is the wattage?

Clarification: The existing fixtures are T-8 32 watts. The new fixtures on the cut sheets are 40 watts.

Question: 10. Being that it is prop 39 is prevailing wage still required?

Clarification: Prevailing wage is required for this project.

Question: 11. Please provide any additional information pertaining the project and step by step instruction for the successful submittal of the estimate.

Clarification: Instructions pertaining to submitting a proposal are found on the Instructions to Bidders section of the RFB.

Question: 12. What are the working hours?

Clarification: This is the time frame for the Prop 39 project.

July 1, 2019: start project

August 9, 2019: finish project

Monday-Friday working time: 6:00am-6:30pm

Saturday working time: 7:00am-3:30pm

Schools are to be done in the order listed below.

1st Lakeview

2nd Lakeland

3rd Paddison

4th William Orr

5th Studebaker

6th Jersey

7th Cresson

Question: 13. What is the inspector allowance?

Clarification: There is no inspector allowance. This is not a DSA project.

Question: 14. Will there be an allowance for damaged or brittle fixtures needing to be replaced?

Clarification: All exterior and interior fixtures are to be replaced, so there is no allowance needed for brittle fixture replacements..

Question: 15. If we do ballast bypass on majority of fixtures but on induction fixtures we need to replace the fixtures is that okay?

Clarification: All exterior fixtures are to be replaced with new LED fixtures. All interior pendant lights are to be replaced with new surface-mount LED fixtures. Ballast bypass is not an option.

Question: 16. Is there a lighting schedule and/or manufacture the school prefers?

Clarification: There is not a preferred vendor. Must match items in the lists for size and equivalent or better functionality (light output and operation) and comply with California Energy Commission handbook and audit requirements.

END OF ADDENDUM

Mission Statement: With a focus on learning, the shared mission of the Little Lake City School District community is to provide a quality education that ensures success for every student

